

Crestline Village Water District

System Report on: 08/31/26

Water Storage (Gal)	Capacity	Gallons/ Foot	Level (FT)	Current Storage	% of Capacity
Beacon I & II	385,354	16,752	20.19	338,223	87.77%
Saxon	337,674	14,679	18.83	276,406	81.86%
Pinecrest I & II	2,063,492	54,302	29.91	1,624,173	78.71%
Zurich	380,500	18,789	19.49	366,198	96.24%
Lakeview	1,230,212	27,955	32.36	904,624	73.53%
Old Mill	705,900	27,151	23.74	644,565	91.31%
Barn	444,443	19,752	20.09	396,818	89.28%
Wilson	983,681	33,915	26.98	915,027	93.02%
Chillon	337,674	14,679	18.12	265,983	78.77%
Brookside	748,067	28,772	22.58	649,672	86.85%
Chamois	1,026,532	39,482	22.51	888,740	86.58%
Total	8,643,529		254.80	7,270,429	84.11%

C.L.A.W.A.	FLOWS - GPM				Production M-T-D (Cubic Feet)
	Timed	Requested	Variance	% Variance	
CF - Crestline	0	0	0	0.00%	0
Mile High 2"	0	0	0	0.00%	0
Mile High 4"	0	0	0	0.00%	0
Pinecrest 2"	0	0	0	0.00%	0
Pinecrest 4"	224	250	(26)	-10.40%	1,165,319
Lake Drive 2"	0	0	0	0.00%	0
Lake Drive 4"	0	0	0	0.00%	0
Camp Seely	22	0	22	0.00%	88,666
Total	224	250	(26)	-10.40%	1,253,985

August Purchases	GPM	Cubic Feet	Wells	GPM	Cubic Feet
Last Year M-T-D:	192.6	1,149,420		292.3	1,744,422
Actual M-T-D:	210.1	1,253,985		278.6	1,662,730
Over/(Under) Last Year:	17.5	104,565.0		(13.7)	(81,692.0)

For Month of: August 2026

WELLS	Production M-T-D (Cubic Feet)	Status
Altdorf	92,148	On
Pioneer-2	45,240	On
Pioneer-1	65,992	On
Old Mill Springs	34,627	On
Maple Springs	97,542	On
Willow Springs	59,997	On
Brookside Springs	52,565	On
Hillside Springs	0	Off
Pinecrest 1 & 2	103,771	On
Pinecrest Vertical	144,065	On
Cypress Vertical	0	Off
Anderson Vertical	107,770	On
Wilson Springs 1 & 2	202,334	On
Wilson Vertical	172,565	On
Felsen Vertical	168,794	On
Horst	148,340	On
Jewel 64	66,697	On
Cathcart	26,839	On
Bergschrund	41,382	On
Electra Vertical	0	Off
Chamois Vertical	32,062	On
	0	0
	0	0
	0	0
Lewter	0	Off
Total	1,662,730	

Total	GPM	Cubic Feet
Last Year M-T-D:	484.9	2,893,842
Actual M-T-D:	488.7	2,916,715
Over/(Under) Last Year:	3.8	22,873.0